



273438

MICHIGAN WATER RESOURCES COMMISSION

BRIEFING MEMO

Bronson Specialties, Inc.
Tool Div. & Bronson Plastics Div.
Bronson, Michigan

January 13, 1976

} — F-15

General

Noncontact cooling water stated to be 0.464 mgd in the company's application dated June 20, 1975, is discharged to Swan Creek via a municipal storm sewer and drain #30. In the manufacture of tools, dies, and molded plastic parts, noncontact cooling water is used in cooling plastic injection molding machines and air compressor after coolers.

City purchased water is consumed for all uses. Sanitary wastes are discharged to the municipal sanitary sewer.

Permit Rationale

Only oil and grease solvent extraction water chemistries are required to be performed by permittee. No timetable is required, nor are thermal limits applicable because of the small load.

Robert F. Babcock

RFB/mc